



正本
ORIGINAL

日期 Date: Mar. 06, 2017 收件日期 Date of Receipt: Mar. 02, 2017 試驗報告 TEST REPORT 土城場區 TUCHENG

報告編號 Report No.: TFF6 數量 Quantity: 1 PC 報告頁次/頁數 Page Order/Pages: (P1/4) 來文字號 Ref. No.: NIL
報告抬頭 Report Title: 試件類別 Item: Filter
地址 Address:

Filter Test Report


1. Filter Descriptions

- (1) Manufacturer :
- (2) Type :
- (3) Sample Name :
- (4) Nominal Dimension : 440 mm x 592 mm x 292 mm
- (5) Media Material : Glass fiber
- (6) Media Color : White

2. Test Conditions

- (1) Test method : AIR FILTER BREACH TEST
- (2) Volume airflow rate : 2500 CFM
- (3) Temperature : 25±2°C
- (4) Humidity : 45±5%

Before Test



After Test



附記: 1. 本報告僅對樣品負責，樣品保留期限為一個月。

Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.

2. 本報告非經本檢測及驗證部書面同意，不得摘錄複製，但全部複製除外。

This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.

3. 試驗報告所載事項不得作為公開廣告及商業推銷之用。

The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所
所長授權核發人:
Authorized by president of
Taiwan Textile Research Institute

Guo-Tsun Jou

Director.

Department of Testing and

Certification

紡織所檢測及驗證部 新
Department of Testing and Certification, Taiwan Textile Research Institute
No. 8, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R. O. C.)
Tel : +886-2-22670321 ext. 7107, 7110
+886-2-22698229, +886-2-22698230
Fax : +886-2-22675108, +886-2-22689839



正本
ORIGINAL

日期: Mar. 06, 2017 收件日期: Mar. 02, 2017 試驗報告 TEST REPORT 土城場區 TUCHENG

報告編號: TFF6 數量: 1 PC 報告頁次/頁數: (P2/4) 來文字號: NIL
Report No.: TFF6 Quantity: 1 PC Page Order/Pages: (P2/4) Ref. No.: NIL
報告抬頭: 試件類別: Filter
Report Title: Item:
地址: Address:

3. Testing Results

Pressure drop (Pa)	Test sample	Descriptions
182	 Back view	The appearance of new filter is normal.
500	 Back view	The appearance of filter is normal.
1000	 Back view	The appearance of filter is normal.

附記: 1. 本報告僅對樣品負責, 樣品保留期限為一個月。

Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.

2. 本報告非經本檢測及驗證部書面同意, 不得摘錄複製, 但全部複製除外。

This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.

3. 試驗報告所載事項不得作為公開廣告及商業推銷之用。
The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所
所長授權核發人:

Authorized by president of
Taiwan Textile Research Institute
Director,
Department of Testing and Certification

紡織所檢測及驗證部 新北市土城區承天路六號
Department of Testing and Certification, Taiwan Textile Research Institute
No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R. O. C.)
Tel : +886-2-22670321 ext. 7107, 7110
+886-2-22698229, +886-2-22698230
Fax : +886-2-22675108, +886-2-22689839



正本
ORIGINAL

日期: Mar. 06, 2017 收件日期: Mar. 02, 2017 **試驗報告** 土城場區
Date: Mar. 06, 2017 Date of Receipt: Mar. 02, 2017 **TEST REPORT** TUCHENG

報告編號: TFF6C069 數量: 1 PC 報告頁次/頁數: (P3/4) 來文字號: NIL
Report No.: TFF6C069 Quantity: 1 PC Page Order/Pages: (P3/4) Ref. No.: NIL
報告抬頭: 試件類別: Filter
Report Title: Item: Filter
地址: Address:

Pressure drop (Pa)	Test sample	Descriptions
1500	 Back view	The appearance of filter is normal.
2000	 Back view	The appearance of filter is normal.
2500	 Back view	The appearance of filter is swollen.

附記: 1. 本報告僅對樣品負責, 樣品保留期限為一個月。

Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.

2. 本報告非經本檢測及驗證部書面同意, 不得摘錄複製, 但全部複製除外。

This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.

3. 試驗報告所載事項不得作為公開廣告及商業推銷之用。

The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所

所長授權核發人:

Authorized by president of

Taiwan Textile Research Institute

Gwo-Tsun Jau

Director.
Department of Testing and
Certification


紡織所檢測及驗證部 新北市土城區承天路六號
Department of Testing and Certification, Taiwan Textile Research Institute
No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R. O. C.)
Tel : +886-2-22670321 ext. 7107, 7110
+886-2-22698229, +886-2-22698230
Fax : +886-2-22675108, +886-2-22689839



正本
ORIGINAL

日期 Date: Mar. 06, 2017 收件日期 Date of Receipt: Mar. 02, 2017 試驗報告 TEST REPORT 土城場區 TUCHENG

報告編號 Report No.: TFFC 數量 Quantity: 1 PC 報告頁次/頁數 Page Order/Pages: (P4/4) 來文字號 Ref. No.: NIL
報告抬頭 Report Title: 試件類別 Item: Filter
地址 Address:

Pressure drop (Pa)	Test sample	Descriptions
3000	 Back view	The appearance of filter is swollen.
3500	 Back view	The appearance of filter is swollen.
4000	  Back view	The appearance of filter is broken.

附記: 1. 本報告僅對樣品負責, 樣品保留期限為一個月。

Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.

2. 本報告非經本檢測及驗證部書面同意, 不得摘錄複製, 但全部複製除外。

This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.

3. 試驗報告所載事項不得作為公開廣告及商業推銷之用。
The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所
所長授權核發人:

Authorized by president of
Taiwan Textile Research Institute

Director.

紡織所檢測及驗證部 新加坡土城區承天路六號
Department of Testing and Certification
Department of Testing and Certification, Taiwan Textile Research Institute
No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R. O. C.)
Tel : +886-2-22670321 ext. 7107, 7110
+886-2-22698229, +886-2-22698230
Fax : +886-2-22675108, +886-2-22689839